

Trout Lake Wind & Solar Energy Pre-feasibility Analysis Summary

Introduction

Since 2005, the Aurora Research Institute (ARI) has researched the wind energy potential for communities in the NWT that are served by diesel. In Trout Lake the ARI has studied the feasibility of both wind and solar energy and compared them with diesel generation.

Assessment of Wind and Solar

The ten-year (2001-2010) average wind speed at Trout Lake's airport was measured to be 2.5 m/s, which is too low for wind energy to be cost effective in the community. The average solar energy potential was estimated at 2.9 kWh/m²/day (daily insolation), which is considered to be good for solar electricity production.

Proposed Wind and Solar Projects

The most optimum wind project sizes for Trout Lake's energy needs were found to be 35 kW to 55 kW. This would help reduce greenhouse gas emissions and save diesel fuel, but would not be cost effective compared to current diesel rates.

Solar systems are more flexible, and so project sizes of 1 to 5 kW (home base grid connected) and 32 kW (utility scale) using generic solar modules on either a fixed frame (adjusting the angle of the modules seasonally is recommended) or on a solar tracker were considered for the solar assessment.

Production and Cost of Wind and Solar Energy

A wind project in Trout Lake will produce 236 to 457 kWh per kW of installed wind energy capacity. The wind energy will cost about \$5.12 to \$7.60 per kWh. This is 13 to 19 times more than the diesel savings of \$0.39 per kWh that the utility needs to achieve for the wind project to be economical.

A home-based solar system in Trout Lake will produce from 1,130 (on a fixed frame, adjusted seasonally) to 1,446 (on a one axis solar tracker) kWh per kW installed. The cost of solar electricity is calculated at \$0.76 (one axis tracker) to \$0.80 (fixed frame) per kWh.

A home-based 2 kW solar system on a fixed frame (adjusted seasonally) will cost \$20,000 and will displace 2,260 kWh of electricity and 686 litres of diesel fuel a year. With a present rate of \$0.854 per kWh for the Trout Lake home owner, the electricity savings represent \$1,930 per year (simple payback of 10 years). If the electricity rate was subsidized at \$0.49 per kWh as in other communities, the net savings would only be \$1,107 per year (the simple payback would be 19 years).

A utility scale solar system of 32 kW will produce the same amount of energy per kW installed as the home-based system but will cost about \$0.64 (fixed frame, adjusted seasonally) per kWh. This cost is 64% more than diesel savings of \$0.39 per kWh that the utility needs to realize for the solar project to be economical. The simple payback for a 32 kW system is about 19 years.

Conclusions

If Trout Lake is considering alternative energy developments, the use of solar energy generation would be a better option than wind energy. Subsidies would be required to make the solar project cost-effective compared to continued diesel generation.

The full Trout Lake Wind and Solar Energy Pre-feasibility Analysis Report is available for download at www.nwtresearch.com

For more information on this or other wind energy studies in the NWT, contact the Aurora Research Institute at:

191 Mackenzie Road
PO Box 1450
Inuvik, NT X0E 0T0
Phone: (867) 777-3298
Fax: (867) 777-4264



Printed March 2012